

TO: Bob Baldwin, Project Manager

JOB SITE: 10613 NE 38<sup>th</sup> Place, Kirkland, WA 98033

SUBJECT: Tree Inventory & Viability Assessment - Report Addendum

DATE: October 14, 2014

PREPARED BY: Scott Baker,  
ASCA Registered Consulting Arborist #414, ISA Board Certified  
Master Arborist PN-0670B, ISA Qualified Tree Risk Assessor

---

### Addendum

The design review board required an access stairway be installed from NE 38th Pl into the parking lot through the root zone of several protected trees. The architect has come up with a solution of installing a 5' wide steel stair atop piers. We agree that this plan will allow the stairs to be built with minimal impact to the root zone of the trees and will allow them to be retained in good condition.

